



Attestation of Conformity

**IEC 60332-3-24 (Cat.C) Fire Retardancy,
of
Tyco AMP NETCONNECT Cable, P/N: 57893**

**Tyco Electronics Raychem N.V.
Diestsesteenweg 692,
B-3010 Kessel-Lo (Leuven), Belgium**

Attestation of Conformity No. 106508

This type of cable has been fire retardancy tested by 3P Third Party Testing according to IEC 60332-3-24 (Cat.c), and complies with all specified requirements of the latest edition of the standard. The Attestation of Conformity is valid for the specific cable sample delivered to 3P with the following identification:

<i>Supplier:</i>	Tyco Electronics Raychem N.V.
<i>Supplier Identification:</i>	Tyco AMP NETCONNECT Cat.7 PiMF600 data cable, P/N: 57893
<i>Sample Marking:</i>	00007 M TYCO AMP NETCONNECT ISO-EN COMPLIANT D1012 AWG23 PRO4 CAT7 LSRZHS/FTP PiMF600 XG SOLID IEC 60332-3-24 0641 881757.01

Hoersholm, 20 November 2006

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 20 November 2006

Paul Villien

Poul Villien
Coordinating Manager