

# Attestation of Conformity

## No. 2003-112 - Data communication cable, Category 6

### Company

Tyco Electronics Denmark A/S  
Gunnar Clausens Vej 36  
8260 Viby J  
Denmark

Tyco Electronics Belgium  
Diestsesteenweg 692  
1030 Kessel-Lo  
Belgium

### Product description

Unshielded cable (UTP), characterised up to 250 MHz  
Horizontal floor wiring cable, 100  $\Omega$   
4 twisted pairs  
23 AWG, halogen free jacket

### Product identification

TYCO AMP NETCONNECT 219585 CAT. 6 LSZH UTP

### Generic cabling standards, cable standards


- ISO/IEC 11801 2<sup>nd</sup> edition (2002) and IEC 61156-5:2002
- EN 50173-1, 2. edition (2002)
- ANSI/TIA/EIA-568-B.2-1

### Technical report


DELTA-E311690-01, DANAK-19J1149

This product has been tested by the EC (European Cabling) group of DELTA and complies with the electrical parameters and the electrical transmission parameters of the requirements of the above specified standards.

Hørsholm, 4 Aug. 2003



Erik Bech  
Test Manager



Claude Videt  
Test Engineer

### DELTA

Danish Electronics,  
Light & Acoustics

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. (+45) 72 19 40 00

Fax (+45) 72 19 40 01

[www.delta.dk](http://www.delta.dk)

