

Certificate

No. z2085b-09-E

Customer:

Tyco Electronics AMP GmbH
Ampèrestr. 7-11
D-63225 Langen

Test sample(s):

- Connector:
TYCO AMP NETCONNECT AMP-TWIST-6_AS SL Jack
Part-no.: 0-1711592-1; 0-1711716-1
- Data Cable (85m):
TYCO AMP NETCONNECT System Cable
AWG 23/1 PR04 CAT7 S/FTP LSFRZH PIMF600 SOLID
Part-no.: 0-0057893-1; 0-1711005-1
- CP-Cord (5m):
TYCO AMP NETCONNECT System Cable
AWG 23/1 PR04 CAT7 S/FTP LSFRZH PIMF600 SOLID
Side A: RJ45-plug; Side B: RJ45-module
Part-no.: 0-1711825-X

Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- TIA/EIA-568-B.2-10 (2008-04)

Results:

Up to a bandwidth of **500 MHz** the sample meet the **Class E_A** limits of the specified standards and regulations.

3-Connector Permanent Link, Class E_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2085b-09-E**, from **September 21th, 2010** and shall only be applicable in conjunction with the test report.

Bexbach, September 21th, 2010



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de