



# Certificate

<b>Customer:</b>	<b>Tyco Electronics</b> Diestsesteenweg 692 B-3010 Kessel-Lo, Belgium
<b>Description:</b>	Wall Outlet <b>TYCO Electronics AMP Netconnect AMP CO Plus Outlet</b> Part-No.: 171148-X and <b>TYCO Electronics AMP Netconnect AMP CO Plus System Insert Cat.7A HS ARJ-45</b> Part-No.: 1711609-X
	Patch Panel <b>TYCO Electronics AMP Netconnect AMP CO Plus Patch Panel</b> Part-No.: 1394573-X and <b>TYCO Electronics AMP Netconnect AMP CO Plus System Insert Cat.7A HS ARJ-45</b> Part-No.: 1711609-X
	Data Cable 90m <b>TYCO Electronics AMP Netconnect AMP DATALAN T150 AWG22 System Cable</b> Part-No.: 1499101-X
	Patchcord 2x 2m <b>TYCO Electronics AMP Netconnect AMP Patch Cord Cat.7A HS ARJ-45</b> Part-No.: 1711563-X
<b>Applied standards:</b>	ISO/IEC 11801 Amendment 1 JTC 1/SC N1255 Information technology – Generic cabling for customer premises

**Results:** Up to a bandwidth of **1000MHz** the sample, a **2-Connector-Channel**, meet the limits of the specified standards and regulations.

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the data cables or connectors are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P1802a-07-E, from October 01<sup>st</sup> 2007** and shall only be applicable in conjunction with the test report.

Bexbach, October 01<sup>st</sup> 2007

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
E-Mail: [info@ghmt.de](mailto:info@ghmt.de)  
<http://www.ghmt.de>